

# AENOR

## Certificate of constancy of performance

CE  
0099

0099/CPR/B85/0142

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

### SUMCAB SPECIALCABLE GROUP, S.L.

registered office	PI PLA DE LLERONA, CL GRAN BRETANYA, 29 08520 LES FRANQUESES DEL VALLÈS (Barcelona - España)
Certified performance	Reaction to Fire of power electric cables for general applications in construction Works.
Harmonized Standard	EN 50575:2014 EN 50575:2014/A1:2016
Designation	Z1C4Z1-K/LIHCH/HSLCH (0,6/1kV)
Trade Mark	SUMSAVE AS (00015)
Reaction to Fire Class	Cca-s1b,d1,a1
Cross-sectional Range	From 1x1,5 mm <sup>2</sup> to 50x1,5 mm <sup>2</sup> ; From 1x2,5 mm <sup>2</sup> to 37x2,5 mm <sup>2</sup> ; From 1x4 mm <sup>2</sup> to 12x4 mm <sup>2</sup> ; From 1x6 mm <sup>2</sup> to 12x6 mm <sup>2</sup> .
Rated Voltage	0,6/1 kV
Production site	Code 661803
Certification scheme	This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonized standard are applied.  This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.
First issued on	2017-07-10
Validity date	2020-07-10

Rafael GARCÍA  
General Manager

Original Electrónico

AENOR INTERNACIONAL S.A.U.  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- www.aenor.com

Authorized control body accredited by ENAC. Accreditation number: OC-P/137