

AENOR

Certificate of constancy of performance

CE

0099

0099/CPR/B85/0135

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

SUMCAB SPECIALCABLE GROUP, S.L.

registered office	PI PLA DE LLERONA, CL GRAN BRETANYA, 29 08520 LES FRANQUESES DEL VALLÈS (Barcelona - España)
Certified performance	Reaction to Fire of power electric cables for general applications in construction Works.
Harmonized Standard	EN 50575:2014 EN 50575:2014/A1:2016
Designation	Z1C4Z1-K/HSLCH/LIHCH (0,6/1kV)
Trade Mark	SUMSAVE AS (00248)
Reaction to Fire Class	Cca-s1b,d1,a1
	See annex for more information.
Production site	Code 25411
Certification scheme	This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonized standard are applied. This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.
First issued on	2017-07-07
Validity date	2020-07-07

Rafael GARCÍA
General Manager

Original Electrónico

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Authorized control body accredited by ENAC. Accreditation number: OC-P/137

AENOR

Certificate of constancy of performance

0099/CPR/B85/0135

Annex to Certificate

Designation Z1C4Z1-K/HSLCH/LIHCH (0,6/1kV)
Trade Mark SUMSAVE AS (00248)
Reaction to Fire Class Cca-s1b,d1,a1

Cross-sectional Range	Rated Voltage
From 2x1,5 mm ² to 30x1,5 mm ² ; From 2x2,5 mm ² to 24x2,5 mm ² ; From 2x4 mm ² to 7x4 mm ² ; From 2x6 mm ² to 7x6 mm ² ; From 2x10 mm ² to 7x10 mm ² ; From 2x16 mm ² to 5x16 mm ² .	0,6/1 kV

First issued on 2017-07-07
Validity date 2020-07-07